


# Lewes BPW power outages April 2017

## IEEE 1366 Statistics


Metric	Apr 2017
SAIDI	0.217
SAIFI	0.00296
CAIDI	73.636
ASAI	99.9994%
Momentary Interruptions	0
Sustained Interruptions	4

## Causes Ranked by Count



Cause	Count	View
Equipment Damage	2	<a href="#">View</a>
Equipment Worn Out	1	<a href="#">View</a>
Squirrel	1	<a href="#">View</a>

## Causes Ranked by Duration



Cause	Duration	View
Equipment Damage	480	<a href="#">View</a>
Squirrel	180	<a href="#">View</a>
Equipment Worn Out	150	<a href="#">View</a>

## Top 4 Outages for the Month

Address	Customers Interrupted	Duration	Customer Minutes of Interruption	Start Date	View
660 Pilottown Rd	3	120	360	04/27/2017	<a href="#">View</a>
59 Sussex Dr	3	60	180	04/14/2017	<a href="#">View</a>
27 Sussex Dr	3	50	150	04/20/2017	<a href="#">View</a>
222 Bay Ave	2	60	120	04/30/2017	<a href="#">View</a>

Total Customers Affected for the Month: **11**

Average Customers Affected per Outage: **2.75**

4/14/17 59 Sussex Drive called to report outage. 3 customers interrupted for a duration of 60 minutes caused by equipment damage

4/20/17 27 Sussex Drive called to report outage. 3 customers interrupted for a duration of 50 minutes caused by equipment worn out

4/27/17 660 Pilottown Road called to report outage. 3 customers interrupted for a duration of 120 minutes caused by equipment damage

4/30/17 222 Bay Ave called to report outage. 2 customers interrupted for a duration of 60 minutes caused by a squirrel.

PRELIMINARY BOARD DOCUMENT