

Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2017	1/23/17	3	5	25	Wind	99.99531%
February 2017	2/18/17	3	4	120	Equipment damage	99.92690%
	2/20/17	3	5	60	Electrical failure	
March 2017	3/10/17	1	3	30	Squirrel	99.97095%
	3/11/17	1	2	60	Squirrel	
	3/17/17	3	1	120	Equipment damage	
April 2017	4/14/17	1	3	60	Squirrel	99.96995%
	4/20/17	1	3	50	Equipment worn out	
	4/27/17	3	3	120	Equipment Damage	
	4/30/17	3	2	60	Equipment Damage	
May 2017	5/2/17	2	5	30	Equipment Damage	99.98223%
	5/17/17	2	1	45	Equipment Damage	
	5/17/17	2	4	45	Equipment worn out	
	5/19/17	2	1	45	Equipment Damage	
	5/23/17	1	5	15	Squirrel	
June 2017	6/6/17	1	3	30	Squirrel	99.93995%
	6/7/17	3	12	90	Human Accident	
	6/15/17	1	5	60	Tree	
	6/15/17	3	6	75	Bird	
	6/16/17	3	1	60	Tree	
July 2017	7/14/17	3	6	90	Vehicle Accident	99.96207%
	7/15/17	3	3	60	Equipment Damage	
	7/18/17	3	1	60	Bird	
	7/23/17	2	1	60	Squirrel	
	7/23/17	4	4	55	Squirrel	

