

Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2018	1/12/2018	3	32	180	Equipment Damage	99.78726%
	1/20/2018	2	5	30	Squirrel	
	1/20/2018	1	1	30	Squirrel	
February 2018	No outages					100%
March 2018	3/6/2018	3	647	150	Equipment Damage	96.53075%
April 2018	4/15/18	4	630	50,400	Tree	72.31603%
	4/18/18		3717	698,796	Utility Maintenance & Repairs	
	4/22/18	1	1	45	Squirrel	
	4/23/18	4	1	20	Squirrel	
May 2018	5/12/18	3	1	45	Equipment worn	99.99839%
June 2018	No outages					100%
July 2018	7/28/18	2	5	60	Bird	99.97213%
	7/29/18	2	8	60	Squirrel	
August 2018	8/5/18	1	4	45	Squirrel	99.98497%
	8/10/18	1	1	120	Equipment Damage	
	8/11/18	4	1	120	Equipment Damage	