

## Work Orders Completed in Prior Month

WO No.	Asset Description	Brief Description	Comments	Work Completed	WO Type
4243	Lewes DO Probes	Weekly DO meter PM	All probes cleaned and calibrated.	04/01/2025	PM
4321	LS #1 U of D	FUWO: Call out for high level at PS#1	PS#1 inspected. Bad relay found and replaced. Station back in normal operation.	04/02/2025	FOLLOW UP
4245	Blowers	Weekly Oil Check	All blowers checked daily.	04/03/2025	PM
4244	Lewes Turbidimeters	Daily Turbidity Meter PM	All meter probes wiped daily.	04/04/2025	PM
4252	Howard Seymour STP	Monthly Material Handling and Storage Inspection	Inspection completed. No issues found.	04/04/2025	PM
4242	Howard Seymour STP	Weekly Universal Waste Inspection	Inspection completed. No changes.	04/07/2025	PM
4291	Gehl Skid Steer	Monthly Rolling Stock PM	Inspection completed.	04/07/2025	PM
4295	Edge Loader Brush	Monthly Rolling Stock PM	Inspection completed. No issues found.	04/08/2025	PM
4226	LS #3 Pilottown Marina	FUWO: Pump Station Monthly Inspection	Stairs swept and housekeeping down around pump station.	04/09/2025	FOLLOW UP
4247	Lewes DO Probes	Weekly DO meter PM	All probes cleaned and calibrated	04/09/2025	PM
4296	Generator, Main Plant	Monthly Generator Inspection	Inspection completed. No issues found.	04/09/2025	PM
4297	Generator	Monthly Generator Inspection	Inspection completed. No issues found.	04/09/2025	PM
4298	Generator	Monthly Generator Inspection	Inspection completed. No issues found.	04/09/2025	PM
4301	Overhead Trolley 1	Hoist Inspection - Monthly	Inspection completed. No issues found.	04/09/2025	PM
4304	Overhead Crane Davit Arm Second Floor	Hoist Inspection - Monthly	Inspection completed. No issues found.	04/09/2025	PM
4229	LS #17 Savannah Road Huling Cove	FUWO: Pump Station Monthly Inspection	Pump seated and operational	04/10/2025	FOLLOW UP
4294	Snowblower	Monthly Rolling Stock PM	Inspection completed. No issues found.	04/10/2025	PM
4302	Overhead Trolley 2	Hoist Inspection - Monthly	Inspection completed. No issues found.	04/11/2025	PM
4303	Hoist	Hoist Inspection - Monthly	Inspection completed. No issues found.	04/11/2025	PM
4306	Blowers	Monthly Blower Inspection / PM	Inspections and PM's completed. No issues found.	04/11/2025	PM
4309	Lewes Turbidimeters	Daily Turbidity Meter PM	All meter probes wiped daily.	04/11/2025	PM
4408	LS #4 Gills Neck Savannah	Call out for high level	High level call out. Operator discovered that pump 2 had lost prime. Operator reprimed pump and stayed onsite to ensure that pump operated and level dropped.	04/11/2025	REACTIVE
4246	Howard Seymour STP	Weekly Universal Waste Inspection	Inspection completed. No changes.	04/14/2025	PM
4249	Howard Seymour STP	Monthly Housekeeping Inspection	Inspection completed. No issues found. All walkways clear and hoses and tools put away.	04/14/2025	PM
4259	LS #1 U of D	Pump Station Monthly Inspection	Both pumps working. Floats operating normally. FOG light.	04/14/2025	PM
4260	LS #2 Pilottown Rodney Ave	Pump Station Monthly Inspection	Both pumps working. High level float needs replaced. FOG light.	04/14/2025	PM
4261	LS #3 Pilottown Marina	Pump Station Monthly Inspection	Both pumps working. Level transducer operating normally.	04/14/2025	PM
4263	LS #5 California Ave	Pump Station Monthly Inspection	Both pumps working. Floats operating normally. FOG medium.	04/14/2025	PM

## Work Orders Completed in Prior Month

WO No.	Asset Description	Brief Description	Comments	Work Completed	WO Type
<b>4264</b>	LS #6 Connecticut Ave	Pump Station Monthly Inspection	Both pumps working. Floats operating normally. FOG light.	04/14/2025	PM
<b>4265</b>	LS #7 Cape Henlopen Dr Pilot Point	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG heavy.	04/14/2025	PM
<b>4273</b>	LS #15 Cape Henlopen Dr Port Lewes	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG light.	04/14/2025	PM
<b>4288</b>	LS #74 Cape Shores	Pump Station Monthly Inspection	Both pumps good. Floats operating normally but did need cleaned. FOG light.	04/14/2025	PM
<b>4289</b>	LS #83 Sandpiper Court	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG medium.	04/14/2025	PM
<b>3905</b>	LS #17 Savannnah Road Huling Cove	FUWO: Pump Station Monthly Inspection		04/15/2025	FOLLOW UP
<b>4220</b>	Lewes DO Probes	Weekly DO meter PM	All probes cleaned and calibrated.	04/15/2025	PM
<b>4251</b>	Howard Seymour STP	Monthly Electrical System Inspection	Inspection completed. No issues to report.	04/15/2025	PM
<b>4267</b>	LS #9 Sussex Drive	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG medium.	04/15/2025	PM
<b>4268</b>	LS #10 Reserves	Pump Station Monthly Inspection	Both pumps good. Floats operating normally but need to be cleaned. FOG medium.	04/15/2025	PM
<b>4269</b>	LS #11 Hoornkill Avenue	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG light.	04/15/2025	PM
<b>4271</b>	LS #13 Schley Avenue at the old Power Plant	Pump Station Monthly Inspection	Pump good. Floats operating normally. FOG light.	04/15/2025	PM
<b>4272</b>	LS #14 Harborview Road	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG light.	04/15/2025	PM
<b>4275</b>	LS #17 Savannnah Road Huling Cove	Pump Station Monthly Inspection	Pump 1 good. Pump 2 needs rebuilt. Failed due to rags clogging pump. Floats operating normally. FOG medium.	04/15/2025	PM
<b>4276</b>	LS #34 Huling Cove	Pump Station Monthly Inspection	Station name being changed to #34. Both pumps in operation. Level transducer operating normally. FOG very heavy.	04/15/2025	PM
<b>4277</b>	LS #18 Drake Knoll	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG light to medium.	04/15/2025	PM
<b>4278</b>	LS #19 Pilottown Village Ocean Blvd	Pump Station Monthly Inspection	Upon inspection found that muffin monster and pump 2 were tripped. Pump and muffin monster both reset. After reset both pumps and muffin monster in operation. Floats ok. FOG heavy.	04/15/2025	PM
<b>4286</b>	LS #32 Canary Creek	Pump Station Monthly Inspection	Both pumps operating. Level transducer operating normally. FOG light. During inspection discovered that one check valve had failed completely and the other was operating but needs replaced.	04/15/2025	PM
<b>4287</b>	LS #33 DNREC Station	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG light. Added chlorine tablet to wet well.	04/15/2025	PM
<b>4307</b>	LS #35 Tower Hill	Pump Station Monthly Inspection	Both pumps good. Level transducer operating normally. FOG light.	04/15/2025	PM
<b>4219</b>	Lewes Exhaust Fans	Monthly Exhaust Fan Inspection		04/16/2025	PM

## Work Orders Completed in Prior Month

WO No.	Asset Description	Brief Description	Comments	Work Completed	WO Type
4262	LS #4 Gills Neck Savannah	Pump Station Monthly Inspection	Both pumps working. Level transducer operating normally. FOG heavy.	04/16/2025	PM
4266	LS #8, American Legion	Pump Station Monthly Inspection	Both pumps good. Level transducer operating normally. FOG medium.	04/16/2025	PM
4270	LS #12 Market Street Devon Inn	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG very heavy.	04/16/2025	PM
4274	LS #16 Henlopen Gardens	Pump Station Monthly Inspection	Both pumps good. Floats operating normally. FOG light.	04/16/2025	PM
4279	LS #20 Monroe Ave	Pump Station Monthly Inspection	E-One station. No issues.	04/16/2025	PM
4280	LS #21 Monroe Ave	Pump Station Monthly Inspection	E-One station. No issues.	04/16/2025	PM
4281	LS #22 Monroe Ave	Pump Station Monthly Inspection	Upon inspection found that pump 1 was leaking and pump 2 was not operating.	04/16/2025	PM
4282	LS #23 Monroe Ave	Pump Station Monthly Inspection	Upon inspection we found the pump 1 was leaking and pump 2 was not running.	04/16/2025	PM
4283	LS #25 Monroe Ave	Pump Station Monthly Inspection	E-One station. No issues found.	04/16/2025	PM
4284	LS #29 Washington Street	Pump Station Monthly Inspection	E-One station. No issues found.	04/16/2025	PM
4285	LS #30 Washington Street	Pump Station Monthly Inspection	E-One station. No issues found.	04/16/2025	PM
4308	Lewes Exhaust Fans	Monthly Exhaust Fan Inspection	Inspection complete. New belts needed on two fans. Vent needs opened in chem building.	04/16/2025	PM
4299	5 Ton Hoist, Process Building	Hoist Inspection - Monthly	Inspection completed. No issues found.	04/17/2025	PM
4300	1 Ton Hoist, Process Building	Hoist Inspection - Monthly	Inspection completed. No issues found.	04/17/2025	PM
4313	LS #8, American Legion	FUWO: Pump Station Monthly Inspection	Bolt replaced on pump rotating assembly. Pump back in operation.	04/17/2025	FOLLOW UP
4315	Blowers	Weekly Oil Check	Oil levels checked daily.	04/17/2025	PM
4258	Howard Seymour STP	Monthly SPCC Inspection	Inspection completed. New spill kit needed near bulk fuel tank.	04/18/2025	PM
4293	Ford F350 Crane Truck	Monthly Rolling Stock PM	Inspection completed. Truck washed. No issues found.	04/18/2025	PM
4314	Lewes Turbidimeters	Daily Turbidity Meter PM	All meter probes wiped daily.	04/18/2025	PM
4394	LS #22 Monroe Ave	FUWO: Pump Station Monthly Inspection	Pulled pump and replaced with spare.	04/18/2025	FOLLOW UP
4256	Howard Seymour STP	Monthly Chemical Processing and Storage Inspection	Inspection completed. No new issues found.	04/21/2025	PM
4290	Pressure Washer	Monthly Rolling Stock PM	Inspection completed. No issues found.	04/21/2025	PM
4257	Howard Seymour STP	Monthly Universal Waste Inspection	Inspection completed. No changes.	04/22/2025	PM
4292	Portable Water Pump, Gas	Monthly Rolling Stock PM	Inspection completed. No issues found.	04/22/2025	PM
4311	Howard Seymour STP	Weekly Universal Waste Inspection	Inspection completed. No changes.	04/22/2025	PM
4317	Lewes DO Probes	Weekly DO meter PM	All probes cleaned and calibrated.	04/22/2025	PM
4248	Howard Seymour STP	Monthly General Safety Inspection	Inspection completed. No safety issues found.	04/23/2025	PM
4253	Howard Seymour STP	Monthly Machinery and Equipment Inspection	Inspection completed. No issues found. Equipment checked and operating properly.	04/23/2025	PM
4255	Howard Seymour STP	Monthly Protective and Emergency Equipment Inspection	Inspection completed. No issues found.	04/24/2025	PM

## Work Orders Completed in Prior Month

WO No.	Asset Description	Brief Description	Comments	Work Completed	WO Type
<b>4395</b>	LS #23 Monroe Ave	FUWO: Pump Station Monthly Inspection	Contacted Freemire to have them bring out new pump. Tech pulled old pump and installed new pump. Also had new control box installed and extension added to pump connections.	04/24/2025	FOLLOW UP
<b>4328</b>	Lewes Turbidimeters	Daily Turbidity Meter PM	All meter probes wiped daily.	04/26/2025	PM
<b>4230</b>	LS #18 Drake Knoll	FUWO: Pump Station Monthly Inspection	Cleaned up area around pump station.	04/28/2025	FOLLOW UP
<b>4236</b>	LS #74 Cape Shores	FUWO: Pump Station Monthly Inspection	Cleaned up area around pump station.	04/28/2025	FOLLOW UP
<b>4250</b>	Howard Seymour STP	Monthly Fire Prevention and Emerg Action Inspctn	Inspection completed. Fire extinguishers all check and signed off.	04/28/2025	PM
<b>4316</b>	Howard Seymour STP	Weekly Universal Waste Inspection Inspection	Inspection completed. No changes.	04/28/2025	PM
<b>4254</b>	Howard Seymour STP	Monthly Training and Recordkeeping Inspection	Inspection completed. All monthly training and records up to date.	04/30/2025	PM
<b>4330</b>	Lewes DO Probes	Weekly DO meter PM	All probes cleaned and calibrated.	04/30/2025	PM

Printed 86 items